



NOTES:

1. QUARRY SPALLS AND CRUSHED ROCK SHALL BE PLACED DIRECTLY FROM TRUCK OR OTHER SUITABLE CONTAINER IN ORDER TO MAINTAIN CLEAN BACKFILL.
2. ALL ROCKERIES OVER 1m IN HEIGHT ARE CONSIDERED A STRUCTURE AND MUST BE LOCATED OUTSIDE OF ALL SETBACK LINES.
3. OPENINGS SHALL BE CHINKED WITH QUARRY SPALLS.
4. ROCKERIES GREATER THAN 1.2m IN HEIGHT SHALL BE DESIGNED BY A GEOTECHNICAL ENGINEER AND REQUIRE B1/B2 & SCHEDULE C PRIOR TO FINAL ACCEPTANCE.

ROCKERY DRAINAGE  
BARRIER



DRAWN: 2002 05 31

REVISED: 2005 10 27

APPROVED BY:

ES - EC - 14