

# MULTI-RESIDENTIAL OCCUPANCIES

The B.C. Fire Code requires building owners/occupants to comply with the requirements on this checklist.

These requirements are in addition to those listed in the Fire Safety & You booklet.

**Multi-Residential uses Include:** Low-rise and high-rise apartment buildings, Condominium complexes and all multiple residential occupancies with common use areas (hallways, foyers, etc.)

## Checklist: Common Fire Service Requirements

- Access:** Abbotsford Fire Rescue Service (AFRS) may request provisions for accessing locked stairwells, service rooms etc.
- Address:** must be visible from road, free of foliage, in a contrasting colour.
- Electrical/mechanical rooms:** must be clearly identified.
- Electrical panels, sprinkler control valves, all other electrical and mechanical appliances:** must be easily accessible and kept clear of storage.
- Fire doors:** must not be blocked or wedged open, including stairwell doors. Fire doors must self-close and latch properly to maintain fire separation.
- Fire hydrants / Fire Dept connections:** must be clearly visible, easily identifiable, serviced at required intervals.
- Fire and life safety systems:** must have up-to-date services performed by qualified professionals and be operating free of deficiencies. These include fire alarm, sprinkler system, fire extinguishers, emergency lighting.
- Fire lane access:** must be kept clear and accessible for fire apparatus.
- Hallways/Exit passages:** must be kept clear of obstructions.
- Personal storage locker area:** must be maintained to not compromise sprinkler coverage, and not contain dangerous goods such as propane cylinders, flammable liquids.
- Storage of combustibles on balconies:** must be maintained to not cause undue fire risk.
- Underground parking area:** must be free of all combustible storage.

### Multi-residential occupancies require FSPs that:

- Are kept on-site, stored in AFRS-provided box with AFRS - approved padlock; accessed in main lobby or other easily identifiable area.
- Are reviewed annually, updated as necessary.
- Contain records of the last 2 years of monthly fire and life safety checks.
- Contain most recent annual fire and life safety service records, performed by a qualified professional, including in-suite device inspection and testing.
- Contain most recent required service records for other building systems such as dryer ducts, emergency generator, radio amplification (if necessary).

## Fire Safety Plans

A Fire Safety Plan (FSP) is a detailed document that covers all aspects of fire safety for a specific building or property.

The FSP will outline:

- Building information including construction and fire protection systems.
- A safe and orderly way for occupants to evacuate the building.
- Proper maintenance and housekeeping required to prevent fires.
- Methods of control that minimize the damage from fires when they do occur.



**City of Abbotsford Fire Rescue Service**

32270 George Ferguson Way, Abbotsford, BC V2T 2L1

T: 604-853-3566 • [www.abbotsford.ca/fire](http://www.abbotsford.ca/fire)

